RELIABILITY COMMITTEE | APRIL 16, 2025 | WESTBOROUGH, MA



2025 Final Draft Forecast

Energy and Seasonal Peak Forecasts

Victoria Rojo



Introduction

- The ISO annually develops 10-year forecasts of energy and demand that are published as part of the <u>Capacity, Energy</u>, <u>Loads</u>, and <u>Transmission (CELT) report</u>
- The ISO has developed a new hourly forecast methodology that will be used for the CELT 2025 report and other annual load forecast publications
 - These forecasts are the main focus of this presentation; however, ISO's 2025 gross load forecast based on pre-existing methodology is also discussed
- Final forecasts will be published in the 2025 CELT Report

CELT 2025 Load Forecast Timeline

Working Group and Committee Meetings

- Load Forecast Committee (LFC)
 - September 27, 2024 Introduction to the 2025 long-term load forecast, updates to forecast data sources, forecast modeling, initial results and next steps
 - November 8, 2024 Enhancements to heating, transportation, and BTM PV forecasts for CELT 2025
 - December 13, 2024 <u>Electrification adoption forecast updates</u>, <u>trend variables in the base load forecast</u>, <u>base load modeling and preliminary results</u>
 - February 21, 2025 <u>Draft electric vehicle forecast</u>, <u>draft heat pump forecast</u>, <u>draft annual energy and peak</u> demand forecast
 - March 28, 2025 Final draft annual energy and seasonal peak forecasts, gross load forecasts for ARAs
- Distributed Generation Forecast Working Group (DGFWG)
 - December 9, 2024 State DG policy updates from MA, CT, RI, VT, NH, and ME, DER Forecast Improvements
 - February 10, 2025 <u>DGFWG DER PV interconnection data update</u>, <u>Draft 2025 PV forecast</u>
 - March 24, 2025 <u>Final 2025 PV forecast</u>, <u>Update on DER storage</u>
- Energy Efficiency Forecast Working Group Meetings (EEFWG)
 - September 30, 2024 <u>EE forecast process changes for CELT 2025</u>, <u>introduction to statistically adjusted</u> end-use (SAE) modeling

ISO-NE PUBLIC

December 9, 2024 – <u>Trend variables in the base load forecast</u>

BACKGROUND & REVIEW

ISO-NE PUBLIC

Long-Term Forecast Components for CELT 2025

- Each of the 4 load components entail distinct modeling steps which have been updated or changed for CELT 2025
- The base load forecast reflects significant updates as discussed at the <u>December 13th LFC meeting</u>
- The HP, EV, and BTM PV forecasts have undergone improvements to enable:
 - Adoption forecasting and potential future accounting at the county level
 - Hourly modeling
 - Inclusion of climate-adjusted weather data

on forecasting based on dGen [™] tool d reductions derived using
historical hourly capacity
Vehicle (EV) Forecast
based adoption forecast
cle types)
d derived from weather-

Key Elements of the Hourly Methodology

Re-defining Gross Load

- $Load_{Gross} = Load_{Net} + BTM PV$
- Historical and forward looking impacts of EE are captured via historical trends and SAE drivers included as inputs to the model

Temporal Granularity

 Modeling includes simulations of all hours for all load components, enabling the forecast to capture the dynamic interplay between components and their profiling

Hierarchical Forecasting

- Regional forecast is the sum of zonal forecasts to capture the spatial diversity of weather and load characteristics
- Zonal EV, HP, and BTMPV forecasts start at the county-level

Improved Base Load Modeling

- A daily energy model that feeds 24 individual hourly models
- Combination of linear regression and neural networks
- Expanded set of weather and calendar explanatory variables

Expanded Weather Data

- Use of ERA5 reanalysis weather data from ECMWF
- Climate-adjusted weather data reflecting 70 weather years
- 23 weather locations, 8 weather concepts

Extended Forecast Horizon

• All load components are forecast out 20+ years, enabling the forecast to support longer-term planning studies

Advancements to Forecast Components

- Development of hourly forecasts
 - Each forecast component is simulated on an hourly basis for the entire forecast horizon
 - Each year's forecast is based on 70 years of climate-adjusted weather
- County-level forecast accounting implemented to EV, HP, and BTMPV forecasts
 - Map illustrates county boundaries overlayed with load zones
 - Red dots indicate weather stations
 - County forecasts utilize weather at station closest to county center
 - County-level forecasts are aggregated to load zones before combining with the base load forecast



Load Forecast Compilation

• Each forecast component (base load, EV, HP, and BTM PV) reflects coincident weather over a 70-year simulation period and are combined into forecasts of net and gross load for each zone and the region



Calculation of Seasonal Peaks



Demand Impacts of Load Components

ISO-NE PUBLIC

Waterfall Approach

- The hourly forecast results in a dynamic interplay of modeled load components
 - Peak hour shifts due to the growth of one component affect the peak attribution of other components
 - Attribution of peak load values to components is path dependent
- A waterfall approach to the attribution of peak load contributions is used to standardize this forecast accounting
- Waterfall method steps (refer to plot):
 - 1. Base = Base peak load value 19,020 MW
 - 2. EV = (Base+EV) Base 24,090 – 19,020 = 5,070 MW
 - 3. HP = Gross (Base+EV)
 - 34,280 24,090 = 10,190 MW
 - 4. BTMPV = Gross Net 34,280 – 33,608 = 672 MW



Final Draft CELT 2025 Forecast

Annual Energy, Summer Peak, and Winter Peak

- The following slides summarize the final draft CELT 2025 annual energy and seasonal, coincident peak demand forecasts resulting from the new hourly forecast methodology
 - The charts and figures presented may still be subject to change prior to publication on May 1, 2025
 - Given that hourly forecasts are net of EE and do not involve a separate EE forecast, the forecasts
 presented herein focus on net energy and demand forecasts
 - A gross load forecast based on pre-existing methodology is included in this presentation starting on slide 33
 - This forecast is required by the tariff to support ICR calculation for the remaining FCM ARAs
- The following inputs are reflected in the results
 - Final refinements to base load modeling inputs since draft results
 - Final 2025 HP and EV forecasts, reflecting minor updates to EV forecast since draft results
 - Final 2025 BTM PV forecasts (impacts net forecast only)
 - 2024 forecast used in draft results
 - Transmission and distribution gross up applied to EV, HP, and BTM PV forecasts, which was not included in draft results
 - 8% gross up applied to seasonal peaks
 - 6% gross up applied to energy
- As part of the hourly forecast, BTM PV forecast now impacts both summer and winter peak demand

FINAL DRAFT ELECTRIFICATION FORECASTS



Final Draft CELT 2025 EV and HP Adoption Forecasts

Updates from CELT 2024

- EV adoption for the CELT 2025 forecast has been revised downward across all vehicle categories
 - Comprehensive vehicle registration data has indicated that prior forecasts have exceeded actual EV registrations
 - Additional details can be found in the <u>Draft 2025 Electric Vehicle Forecast</u>
- HP adoption has been updated to align with the most recently available program and policy data
 - Connecticut:
 - 30% reduction in overall adoption
 - New Hampshire:
 - Greater emphasis placed on partial-displacement adoption
 - Massachusetts:
 - Greater emphasis placed on full-displacement adoption
 - 15% reduction in overall adoption
 - Additional details can be found in the <u>Draft 2025 Heat Pump Forecast</u>

Final Draft 2025 EV Adoption Forecast

Cumulative EV Stock for New England



Final Draft 2025 Residential Space Heating Adoption

Incremental HP Adoption by State



Final Draft 2025 Electrification Forecasts

- Final draft 2025 electrification forecasts assume reduced EV and HP adoption relative to 2024 CELT assumptions
- The plot compares the electrification impacts on regional annual energy and 50/50 winter and summer peak demand
 - EV (top) and HP (bottom)
- Aside from changes to adoption assumptions, the hourly forecast reveals:
 - Greater HP impacts on winter peak demand due to morning peaks becoming prevalent by the early 2030s
 - Lower EV impacts on winter and summer demand (per EV adopted)

New England



FINAL DRAFT 2025 ANNUAL ENERGY FORECAST

ISO-NE PUBLIC

Annual Net Energy Forecast

New England – Final Draft CELT 2025 Vs. CELT 2024

Year	Net CELT 2024 (GWh)	Net CELT 2025 (GWh)	Change (GWh)	Change (%)	180,000
2025	119,285	117,262	-2,023	-1.7%	170,000
2026	120,106	117,829	-2,277	-1.9%	160,000
2027	121,298	118,591	-2,707	-2.3%	
2028	123,720	119,559	-4,161	-3.5%	
2029	125,741	120,659	-5,082	-4.2%	140,000
2030	128,655	122,044	-6,611	-5.4%	
2031	131,983	123,747	-8,236	-6.7%	
2032	136,126	125,761	-10,365	-8.2%	120,000
2033	140,001	128,034	-11,967	-9.3%	110,000
2034		130,665			

ISO-NE PUBLIC

Final Draft 2025 Annual Energy Forecasts

New England - Summary

Year	Base (GWh)	Transportation Electrification* (GWh)	Heating Electrification* (GWh)	Gross (GWh)	BTM PV (GWh)	Net (GWh)
2025	122,662	224	692	123,578	-6,316	117,262
2026	122,843	663	1,188	124,693	-6,864	117,829
2027	123,033	1,160	1,743	125,936	-7,346	118,591
2028	123,331	1,761	2,365	127,457	-7,898	119,559
2029	123,619	2,499	3,060	129,178	-8,519	120,659
2030	123,935	3,398	3,846	131,179	-9,136	122,044
2031	124,271	4,472	4,748	133,491	-9,744	123,747
2032	124,626	5,724	5,773	136,123	-10,362	125,761
2033	124,979	7,148	6,867	138,994	-10,961	128,034
2034	125,368	8,735	8,049	142,152	-11,487	130,665

* Electrification forecasts are included in both gross and net peak forecasts.

FINAL DRAFT 2025 SUMMER PEAK DEMAND FORECAST

ISO-NE PUBLIC

Summer Net 50/50 Peak Forecast

New England – Final Draft CELT 2025 Vs. CELT 2024



ISO-NE PUBLIC

Final Draft 2025 Summer Peak Forecasts

New England 50/50 - Summary

Year	Base (MW)	Transportation Electrification* (MW)	Heating Electrification* (MW)	Gross (MW)	BTM PV (MW)	Net (MW)
2025	26,391	27	2	26,421	-1,742	24,679
2026	26,463	67	6	26,536	-1,749	24,787
2027	26,542	113	11	26,665	-1,760	24,906
2028	26,680	181	17	26,878	-1,793	25,085
2029	26,876	254	25	27,155	-1,807	25,348
2030	27,067	341	34	27,442	-1,800	25,642
2031	27,242	429	46	27,717	-1,799	25,918
2032	27,411	542	62	28,014	-1,792	26,223
2033	27,596	670	79	28,345	-1,767	26,578
2034	27,792	832	101	28,725	-1,742	26,983

* Electrification forecasts are included in both gross and net peak forecasts.

Final Draft 2025 50/50 and 90/10 Forecasts

Summer Net Peak





FINAL DRAFT 2025 WINTER PEAK DEMAND FORECAST



Winter Net 50/50 Peak Forecast

New England – Final Draft CELT 2025 Vs. CELT 2024



Final Draft 2025 Winter Peak Forecasts

New England 50/50 - Summary

Year	Base (MW)	Transportation Electrification* (MW)	Heating Electrification* (MW)	Gross (MW)	BTM PV (MW)	Net (MW)
2025	19,750	6	191	19,948	0	19,933
2026	19,772	92	433	20,297	0	20,258
2027	19,794	188	736	20,717	-14	20,703
2028	19,812	300	1,093	21,204	-31	21,173
2029	19,829	436	1,528	21,793	-37	21,755
2030	19,850	645	1,929	22,423	-95	22,329
2031	19,873	911	2,347	23,132	-169	22,962
2032	19,899	1,126	3,132	24,157	-274	23,883
2033	19,918	1,412	3,886	25,215	-384	24,831
2034	19,969	1,696	4,820	26,485	-516	25,969

* Electrification forecasts are included in both gross and net peak forecasts.

Final Draft 2025 50/50 and 90/10 Forecasts *Winter Net Peak*





GROSS LOAD FORECAST FOR CALCULATING ICR FOR UPCOMING ARAS

ISO-NE PUBLIC

CELT 2025: Pre-Existing Forecast Methodology

- Calculation of ICR for the remaining FCM ARAs will be supported by a gross load forecast based on the pre-existing (pre-CELT 2025) forecast methodology
 - Gross load stems from reconstituting for BTM PV and PDRs
 - Separate models for energy and seasonal peaks
 - Details on the pre-existing forecast methodology can be found in this presentation
- Input data
 - Reconstitution for PDR resources based on FCA 18 CSOs
 - CELT 2025 EV and HP forecasts
 - Load, weather, economic data through end of 2024
- Reporting of gross load forecast values generated using the pre-existing methodology will be confined to specific tabs within the CELT Report and Forecast Data Workbook
- The charts and figures presented may still be subject to change prior to publication on May 1, 2025



Pre-Existing Methodology

CELT 2025 PDR Reconstitution for New England



Pre-Existing Methodology

CELT 2025 50/50 Gross Peak Forecast



ISO-NE PUBLIC

Pre-Existing Methodology

CELT 2025 Gross Load Forecast Values for ARAs

- Upcoming ARA events will only use forecast values relevant to the 2026-2027 and 2027-2028 capacity commitment periods (CCPs)
- The values below *are draft and may be subject to change* prior to final publication

Year (Winter Start Year)	Summer 50/50 Peak (MW)	Summer 90/10 Peak (MW)	Winter 50/50 Peak (MW)	Winter 90/10 Peak (MW)	Annual Energy (GWh)
2026	27,533	29,401	22,556	23,469	134,756
2027	27,645	29,522	22,979	23,998	135,998

LOAD FORECAST REPORTING

ISO-NE PUBLIC

Load Forecast Reporting

- The long-term load forecast is published across three workbooks available on the ISO webpage
 - CELT Report
 - Contains a subset of load forecast data, for ISONE as a whole
 - Forecast Data workbook
 - Contains detailed reporting of forecast results over 10-year horizon
 - Forecast Itemization workbook
 - Contains further details on forecast components over 10-year horizon
- For the CELT 2025 forecast, modifications will be made to how the load forecast is reported

- CELT Report
 - Removal of lines related to the EE forecast
 - Forecast values reported in the CELT report will be largely unchanged
- Forecast Data workbook
 - Workbook tabs will be consolidated to reflect data-friendly formatting
 - Changes implemented for CELT 2025 are intended to set the stage for expanded and enhanced reporting in the future
 - Will include reporting of forecast results over 20-year horizon
- Forecast Itemization workbook
 - This product will be retired
 - Data will now be integrated into the Forecast Data workbook

Forecast Data Workbook

Conceptualization of Improvements for CELT 2025

Forecast Data 2024

2024 CELT F	orecast Deta	ail: ISONE Co	ontrol Area, Ne	w England S	states, RSP	Sub-areas, and	SMD Load Z	ones
			SUMME	ER PEAK(MW)				
	GRO	ee		GROS	S-PV		NE	т
ISO-NE	50/50	90/10	PV	50/50	90/10	EE	50/50	90/10
2024	27.424	29.254	1.097	26.327	28,158	1.775	24.553	26.383
2025	27,593	29,434	1,141	26,453	28,293	1.873	24,579	26,419
2026	27,835	29,688	1,161	26,674	28,526	1,972	24,702	26,554
2027	28,088	29,953	1,173	26,916	28,780	2,070	24,845	26,710
2028	28,376	30,254	1,199	27,178	29,055	2,102	25,076	26,954
2029	28,700	30,592	1,218	27,481	29,373	2,117	25,364	27,256
2030	29,058	30,966	1,236	27,823	29,730	2,117	25,706	27,613
2031	29,453	31,377	1,253	28,201	30,124	2,101	26,100	28,023
2032	29,886	31,826	1,269	28,616	30,556	2,069	26,547	28,488
2033	30,359	32,313	1,284	29,075	31,029	2,023	27,052	29,007
CAGR	1.1	1.1	1.8	1.1	1.1	1.5	1.1	1.1
STATES:								
ст	50/50	90/10	PV	50/50	90/10	EE	50/50	90/10
2024	6,964	7,400	217	6,747	7,183	448	6,299	6,735
2025	6,983	7,420	243	6,741	7,177	473	6,268	6,705
2026	7.016	7 450	260	6 740	7 106	409	6 251	6 600

- Formatted columns and rows with spaces, merged cells, and mixed data types
- Multiple sheets are needed to support summer and winter values
- Blocks for each subregion
- Lack of adaptability to future needs
 - Adding granularity or new concepts entails adding blocks of data and new data tabs

NEW Forecast Data 2025

Region	Year	Season	Coincidence	Percentile	Base	EV	HP	Gross	BTMPV	Net
ISONE	2025	summer	СР	50	26,391	27	2	26,421	1,742	6,218
ISONE	2025	summer	CP	90	27,555	23	2	27,581	1,904	24,679
ISONE	2025	winter	СР	50	19,750	6	191	19,948	0	6,374
ISONE	2025	winter	CP	90	20,662	7	215	20,885	6	25 <mark>,</mark> 677
СТ	2025	summer	СР	50	6,556	6	0	6,562	345	4,795
СТ	2025	summer	CP	90	6,734	5	0	6,740	367	19,933
СТ	2025	winter	СР	50	4,766	2	44	4,813	0	5,073
СТ	2025	winter	СР	90	5,027	2	42	5 <i>,</i> 070	0	20,879
СТ	2025	summer	NCP	50						
СТ	2025	summer	NCP	90						

- Columns contain a single data type
- Meta data columns provide concise identification of desired data elements
- Data can be easily extracted in Excel by applying filters, or can be processed programmatically
- Seamless reporting of large datasets
- Adaptability to future needs

ISO-NE PUBLIC

- Reporting of additional granularity or more forecast years simply adds more rows
- Reporting of new concepts or meta data attributes entails new columns

Forecast Data Workbook

Replaced Tabs

Tab in Forecast Data 2024	NEW Tab* in Forecast Data 2025		
2A Summer (MW)			
2B Winter (MW)	Casaanal Daala		
7 Distrbn	Seasonal Peaks		
12 FC			
4 Mnth Peak	Monthly Peaks		
2C Energy (GWh)	Francis		
6 Mnth NEL	спегву		
16 Electrification	Seasonal Peaks / Energy		

ISO-NE PUBLIC

* Exact naming of tabs in the Forecast Data 2025 workbook will be subject to finalization, and may change.

Forecast Data Workbook

Discontinued Tabs

Tab in Forecast Data 2024	Description of Existing Tab	NEW Reference Tab* in Forecast Data 2025
10g Gross Diff	Formatted tables of differences between energy	This can more easily and comprehensively be
10n Net Diff	values for select load components, for the current and prior forecast vintage	extracted utilizing the new "Energy" tab
14 Summary	 Formatted table of differences between select peak values, for select load components, and percentiles, for the current and prior forecast vintage 	This can more easily and comprehensively be extracted utilizing the new "Seasonal Peaks" tab
15 PV EE	 Formatted table of differences between energy and demand values, for the EE and BTM PV forecasts, for current and prior forecast vintages The EE forecast has been discontinued as of CELT 2025 	BTMPV forecast values can be found in the new "Energy", "Seasonal Peaks", and "Monthly Peaks" tabs

ISO-NE PUBLIC

* Exact naming of tabs in the Forecast Data 2025 workbook will be subject to finalization, and may change.

Next Steps

- The final CELT 2025 forecast will be published on May 1, 2025
 - CELT Report (<u>CELT webpage</u>)
 - Forecast Data workbook (Load Forecast webpage)
 - Slide decks describing the final EV and HP forecasts (Load Forecast webpage)

Questions





Acronyms

ASOS	Automated Surface Observing System	EIA	Energy Information Administration
ARA	Annual reconfiguration auction	EV	Electric Vehicle
AEO	EIA's Annual Energy Outlook	GCM	Global Climate Model
BTMPV	Behind the meter photovoltaic	FCM	Forward Capacity Market
CDD	Cooling degree day	GWH	Gigawatt hour
CELT	Capacity, Energy, Load, and Transmission	HDD	Heating degree day
СОР	Coefficient of performance	НР	Heat pump
CSO	Capacity Supply Obligation	ICR	Installed Capacity Requirement
DER	Distributed energy resource	IPSL	Institut Pierre-Simon Laplace (Climate Modelling Center)
DGFWG	Distributed Generation Forecast Working Group	LFC	Load Forecast Committee
ECMWF	European Center for Medium-Range Weather Forecasts	MAPE	Mean absolute percent error
EE	Energy Efficiency	MW	Megawatt
EEFWG	Energy Efficiency Forecast Working Group	PDR	Passive Demand Resource
EPRI	Electric Power Research Institute	SAE	Statistically-adjusted end-use
ERA5	ECMWF Reanalysis Version 5	SSP	Shared Socioeconomic Pathway

